

Utility Name	Fire Start		Location		Material of Origin	Land Use at Origin	Fire		Utility Facility		Outage		Suspected Cause								
	Date	Time	Latitude	Longitude			Size	Suppressed by	Suppressing Agency	Facility Identifier	Other Comp Assets	Voltage	Equipment Involved With Outage	Type	Was There an Outage	Date	Time	Suspected Ignition Cause	Equipment / Facility Failure	Contact From Object	Facility Contacted
SDG&E	1/29/20	19:00	33.4148620	-117.5810280	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Camp Pendleton FD	Z102041	230V	Lightning Arrestor	Overhead	Yes	1/29/20	18:00	Equipment/Facility Failure	Other			Weather
SDG&E	9/11/20	1:30	32.7910060	-116.9194010	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Heardland Fire	P4774334	120V	Conductor	Overhead	Yes	9/11/20	1:13	Equipment/Facility Failure	Splice/Clamp/Connector			Outside Force
SDG&E	2/26/20	6:17	32.9144000	-116.8400000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	P372556	120V	Lightning Arrestor	Overhead	Yes	2/26/20	5:17	Equipment/Facility Failure	Lightning Arrestor			Unknown
SDG&E	9/17/20	8:52	33.2724900	-117.9294460	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P515883	120V	Conductor	Overhead	Yes	9/17/20	8:52	Contact From Object				Other
SDG&E	8/31/20	2:51	32.6581380	-117.9777130	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Chula Vista	P83770	120V	Conductor	Overhead	Yes	9/3/20	1:43	Contact From Object	Balloons			Outside Force
SDG&E	6/2/20	18:00	33.0700000	-116.8630000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Cal Fire	P111476	120V	Conductor	Overhead	Yes	6/2/20	18:00	Contact From Object	Vehicle			Human Error
SDG&E	6/3/20	11:17	33.1244000	-117.5250000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Escondido	P214414	120V	Transformer	Overhead	Yes	6/3/20	11:17	Contact From Object	Pole			Electric Facility
SDG&E	6/26/20	5:50	33.8333900	-117.6188900	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Camp Pendleton FD	Z224551	230V	Conductor	Overhead	Yes	6/26/20	5:50	Unknown				Unknown
SDG&E	7/5/20	14:08	33.0871880	-116.9855210	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	SDG&E Cal Fire	P145263	120V	Lightning Arrestor	Overhead	Yes	7/5/20	23:55	Equipment/Facility Failure	Lightning Arrestor			Unknown
SDG&E	7/17/20	16:30	33.0903110	-116.9797720	Vegetation	Rural	Less Than 25 Acres	Customer		P115116	880V	Transformer	Overhead	Yes	7/17/20		Contact From Object	Animal			Electric Facility
SDG&E	7/26/20	13:44	32.8190410	-116.9561490	Vegetation	Urban	Less Than 25 Acres	Customer		P101639	120V	Fuse	Overhead	Yes	7/26/20	13:44	Equipment/Facility Failure	Fuse			Unknown
SDG&E	7/29/20	17:14	33.2270000	-116.9750000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P818398	120V	Conductor	Overhead	Yes	7/29/20	17:12	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown
SDG&E	8/1/20	11:11	32.6310000	-116.1740000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P40248	120V	Other	Overhead	Yes	8/1/20	11:10	Equipment/Facility Failure	Other			Unknown
SDG&E	8/18/20	13:18	32.6248000	-117.5960310	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Chula Vista	P102585	120V	Switch	Overhead	Yes	8/18/20	13:29	Equipment/Facility Failure	Switch			Unknown
SDG&E	8/22/20	13:38	33.3744160	-116.7739400	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P31591	Secondary	Conductor	Overhead	Yes	8/22/20	13:38	Equipment/Facility Failure	Conductor			Unknown
SDG&E	8/31/20	14:00	33.1950000	-117.0055440	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Escondido	P310132	120V	Conductor	Overhead	Yes	8/31/20	14:08	Contact From Object				Other
SDG&E	9/2/20	19:30	33.8620000	-117.1360000	Vegetation	Rural	Less Than 25 Acres	Utility		P215201	120V	Conductor	Overhead	Yes	9/2/20	19:30	Equipment/Facility Failure	Splice/Clamp/Connector			None
SDG&E	9/4/20	20:30	33.9858210	-116.9521710	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P216156	120V	Conductor	Overhead	Yes	9/4/20	20:30	Contact From Object	Vehicle			Other
SDG&E	9/5/20	14:30	32.7930000	-116.9670000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Heardland Fire	P194421	120V	Conductor	Overhead	Yes	9/5/20	14:30	Contact From Object				Outside Force
SDG&E	9/6/20	23:00	33.0864840	-117.0237540	Vegetation	Urban	Less Than 25 Acres	Fire Agency	NCFPD	P319486	120V	Transformer	Overhead	Yes	9/6/20	23:00	Equipment/Facility Failure	Transformer			None
SDG&E	9/12/20	6:30	33.1055560	-117.0002200	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		P614833	120V	Lightning Arrestor	Overhead	Yes	9/12/20	6:30	Equipment/Facility Failure	Lightning Arrestor			None
SDG&E	9/12/20	7:00	33.9187000	-116.9800000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P145831	120V	Capacitor Bank	Overhead	Yes	9/12/20	7:00	Equipment/Facility Failure	Capacitor Bank			None
SDG&E	9/17/20	10:00	33.1101320	-117.2683310	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Carlsbad	P202732	120V	Conductor	Overhead	Yes	9/17/20	10:00	Equipment/Facility Failure	Other			None
SDG&E	9/30/20	10:46	33.1054890	-116.8913395	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Cal Fire	P619632	Secondary	Conductor	Overhead	Yes	9/30/20	10:45	Equipment/Facility Failure	Conductor			Unknown
SDG&E	#####	15:00	33.0270000	-116.8900000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	CAL FIRE	P612927	120V	Lightning Arrestor	Overhead	No			Equipment/Facility Failure	Lightning Arrestor			Unknown
SDG&E	#####	16:51	32.8600000	-116.8000000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	USP'S CNF	P257762	120V	Lightning Arrestor	Overhead	Yes	10/14/20	16:55	Contact From Object				Outside Force
SDG&E	#####	9:51	32.6780000	-116.8600000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P227054	120V	Other	Overhead	Yes	11/1/20	9:00	Equipment/Facility Failure	Guy/Span Wire			Unknown
SDG&E	#####	9:10	33.1040000	-117.1210000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	NCFPD	P181627	120V	Lightning Arrestor	Overhead	Yes	11/20/20	9:10	Equipment/Facility Failure	Lightning Arrestor			Unknown
SDG&E	12/3/20	11:56	33.1760000	-117.1541000	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	NCFPD	P184669	120V	Conductor	Overhead	Yes	12/3/20	11:56	Equipment/Facility Failure	Pole			Weather